

Annexure C

PROFORMA - SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

CERTIFICATE NO- 159 / camp / lab - 1

DATED- 21/11/2025

It is certified that an inspection team headed by Assistant Engineer, Shashank Pandey from U.P. Jal Nigam Gorakhpur inspected the Udaya Public School, Bargadhi, Bhathat, Gorakhpur on 21/11/2025 and on the basis of Water Test Report (Attached) bearing no 159/camp/lab-1 dated 21/11/2025 of District Water Analysis Laboratory Jal Nigam Gorakhpur (PHED Lab) certified that the Udaya Public School, Bargadhi, Bhathat, Gorakhpur has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of 21/11/2025 to 20/11/2026

Santosh Kumar

Signature With Seal:-

[Signature]

Name :- Shashank Pandey

Designation:- Assistant Engineer

To,
Manager
Udaya Public School,
Bargadhi, Bhathat,
Gorakhpur, 273306

[Signature]
PRINCIPAL
Udaya Public School
Bargadhi-Bhathat, Gorakhpur

[Signature]
MANAGER
Udaya Public School
Bargadhi-Bhathat, Gorakhpur



District Level Water Analysis Laboratory,
U.P. Jal Nigam (Rural), Gorakhpur
Address: EWS 388,389,390 Rapti Nagar Phase-1, Medical Road,
Gorakhpur(U.P)-273003



TC-16928

CHEMICAL SAMPLE TEST REPORT

Rept. No	159 /Camp / Lab-1	Date:	21/11/2025	Page No	1/1
Customer Details					
Office Name and Address	Udaya Public School, Bargadhi, Bhathat, Gorakhpur				
Ref Letter No & Date	15/11/2025				
Basic details of sample					
District	Gorakhpur	Block	--		
Gram Panchayat	--	Village	--		
Habitation	--	Location	Bargadhi, Bhathat, Gorakhpur		
Water Source	R.O.	Sample Code	(C/25/11/09)		
Quantity of Sample	1000 ml	Date of S.C.	17/11/2025		
Receiving Date	17/11/2025	S. Collector	Svatantra Kumar		
Sample Depositor	Svatantra Kumar				
Analysis Start Date	18/11/2025	Analysis Completion Date	18/11/2025		

Environmental Condition

Temperature	24.3°C	Relative Humidity	50%
-------------	--------	-------------------	-----

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Odour	Agreeable		Agreeable	Agreeable	IS 3025 (Part 5):2018
2	Turbidity	0.56	NTU	1	5	IS 3025 (Part 10):2023
3	pH (25°C)	7.01	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
4	Total Dissolved Solids	82	mg/L	500	2000	IS 3025 (Part 16):2023
5	Total Hardness	48	mg/L	200	600	IS 3025 (part 21):2023
6	Total alkalinity	56	mg/L	200	600	IS 3025 (Part 23):2023
7	Chloride as Cl	18	mg/L	250	1000	IS 3025 (Part 32):2003
8	Calcium	16	mg/L	75	200	IS 3025 (Part 40): 2024
9	Magnesium	1.948	mg/L	30	100	IS 3025 (Part 46): 2023
10	Sulphate	3.246	mg/L	200	400	APHA 24th Edition 4500-SO ₄ Method F. Turbidimetric Method 2023
11	Nitrate	0.298	mg/L	45	No relaxation	APHA 24th Edition 4500-NO ₃ Method B UV Screening Method 2023
12	Iron	0.010	mg/L	1	No relaxation	APHA 24th Edition 3500-Fe Method B Phenanthroline Methods 2023
13	Fluoride	BDL	mg/L	1.0	1.5	APHA 24th Edition 4500-F Method C (Electrode Method):202300
14	Arsenic	BDL	mg/L	0.01	No Relaxation	APHA 24th Edition 3500 Method B (Silver Diethyldithiocarbamate Method)

BDL- Below Detection Limit, NA- Not Analyzed

** Parameter(s) above permissible limit are in bold digits.

- Note:
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non - perishable items only) from the date of issue of tests reports unless.
 5. Sample collected by the laboratory.

Vishal Pandey
Review By

S. Pandey
Authorized Signatory

Laboratory Contact details: Email-labgorakhpur@gmail.com

Contact: (+91) 94561988

End of Report

PRINCIPAL
Udaya Public School
thi-Bhathat, Gorakhpur

MANAGER
Udaya Public School
Bargadhi-Bhathat, Gorakhpur



46

District Level Water Analysis Laboratory,
U.P. Jal Nigam (Rural), Gorakhpur
Address: EWS 388,389,390 Rapti Nagar Phase-I, Medical Road, Gorakhpur(U.P)-273003

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No	159 /Camp / Lab-1	Date:	21/11/2025	Page No	1/1	
Customer Details						
Office Name and Address		Udaya Public School, Bargadhi, Bhathat, Gorakhpur				
Ref Letter No & Date		15/11/2025				
Basic details of sample						
District	Gorakhpur	Block	--			
Gram Panchayat	--	Village	--			
Habitation	--	Location	Bargadhi, Bhathat, Gorakhpur			
Water Source	R.O	Sample Code	(C/25/11/09)			
Quantity of Sample	500 ml	Date of S.C.	17/11/2025			
Receiving Date	17/11/2025	S. Collector	Devendra Nath Yadav			
Sample Depositor	Devendra Nath Yadav					
Analysis Start Date	17/11/2025	Analysis Completion Date	19/11/2025			
Technical Data of Analysis						
Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH (25°C ± 2°C)	7.01		6.5-8.5	No relaxation	IS 3025 (Part 11):2017
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025 (PART 26) : 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 rd Edition :2017
4	E.Coli	0	CFU	0	CFU	APHA 23 rd Edition :2017
Result : Satisfactory						Remark: Potable
Note 1. This Certificate refers only to the particular sample(s) submitted for testing.						
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.						
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.						
4. Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of tests reports unless.						
Analysed By				Authorized Signatory		
Laboratory Contact details: Email-labgorakhpur@gmail.com				Contact - +91 8604561988		

End of the Report

PRINCIPAL
Udaya Public School
Bargadhi-Bhathat, Gorakhpur

MANAGER
Udaya Public School
Bargadhi-Bhathat, Gorakhpur